

ENGINEERING CONSULTANCY CENTRE
Regional Engineering College

Tiruchirappalli - 620 015, Tamil Nadu, India.

Chairman
Dr. P. Aravindan
Principal



Phone 553181-83
Fax 0431 - 552133
Cable: TREC
E-mail arvind@rect.cnet.in

31-1-2000

To
M/s. Apollo Meters Pvt. Ltd.,
No. 24, Renganathan Street, Hasti Tower,
First Floor A - Flat, T.Nagar,
Chennai - 600 017.

Sir,

Sub: Flow control valve-test report-reg.

Ref: Your letter No. Nil Dated 30/12/99.

TEST REPORT

The flow control valve (15lt) supplied by M/S Appolo Meters Pvt., Ltd, Chennai was tested in the hydraulics laboratory and following is the result.

1. Minimum operable pressure in which the given valve functions is 0.01 kg/cm^2
2. The pressure loss is zero upto a discharge of 9.5 lpm and it is 0.025 kg/cm^2 at 11 lpm and 0.05 kg/cm^2 at 12.5 lpm.

S. Krishnamoorthi
31/1/2000
Prof S.Krishnamoorthi
Assistant Professor / Civil